

Datasheet

Parameters

Electric Parameters:		
Working power	DC15~30V	
Static power consumption	15mA/DC24V	
Dynamic power consumption	40mA/DC24V	
Output channel	8CH/10A	
Relay	16A Magnetic latching relay	
Max current in each channel	10A	
Electronic life time of relay	>60000 (Resistance Load)	
Protection	Connect a breaker in each channel	
Environmental Conditions:		
Working temperature	-5°C~45°C	
Working relative humidity	Up to 90%	
Storage temperature	-20°C~+60°C	
Storage relative humidity	Up to 93%	
Approved		

CE

RoHS

Production Information:	
Dimensions	144×90×66 (mm)
Weight	361g
Housing material	Nylon, PC
Installation	35mm DIN rail installation
Protection degree	IP20

Installation Step

- 35mm DIN rail Installation, inside DB box.
- Mark up each output connection cable.
- Connect the load and HDL Buspro cable.
- Check if there is any short circuit in output connection cable.
- Check the HDL Buspro connection, avoid any mistakes.
- Isolate the high power and low power.
- Tighten the screw again for all of terminal
- Recommended load type and power

Motors:	1H (1HP=746W)
Incandescent lamp load:	1600 W
Inductive transformer :	1000 W
Electronic transformer:	800 W
Halogen lamp 230 V	1600 W
Mercury-vapour lamp	
* Uncompensated luminaire:	1000 W
* Parallel compensated :	800 W
Fluorescent lamp T5 / T8	
* Uncompensated luminaire:	1000 W
* Parallel compensated :	800 W
* DUO lamp :	800 W
Dulux lamp	

Overview



HDL-MR0810.432 Intelligent Relay Module, has 16A launching relay inside, Zero power consumption and high reliability. The relay's communication interface is HDL Bus Pro, which is based on RS485 protocol.

Functions

- 8-channel Relay output unit.
- Scene controller function available.
- Up to 8 separate areas.
- Each area has 16 scenes with maximum running time of 60 minutes.
- Each channel has light protection delay (0-60 minutes).
- Each channel has batch turn-on delay(0-25 seconds).
- Each channel has manual control for relay unit.
- You can select specified scene or scene before power off when the device restarts
- Supports easy programming and HDL Buspro online upgrading.
- Communication: HDL Buspro

Important Notes

- Bus cable HDL Buspro/KNX cable, 0.8mm single-core copper cable.
- Bus Connection Series connection (hand by hand)
- Output Channel The following list is the recommended load for output channel. To protect the relay, please connect a 10A breaker for each channel.

HDL Buspro Definition for Cable

HDL Buspro	HDL Buspro/KNX
DC24V	Red
COM	Black
DATA-	White
DATA+	Yellow



* Uncompensated luminaire: *Parallel compensated :


1000 W


800 W



Datasheet | 10A Relay Module | HDL-MR0810.432

Dimensions and Wiring





Indicator for module: Flickers when the module is working properly. Keep pressing the indicator for 3 seconds, it will turn to red, then user can read and modify the address of the module in the HDL Bus Pro set up software.

Steps for easy programming mode:

- 1. Pressing the programming button for about 10s, all output channel will be turned off automatically, indicator will flicker fast, enter easy programming mode.
- 2. Now the panel shows "programming", then press Button 9, 10 of DLP switch together, the panel will display "external programming".
- 3. Keep pressing the indicator for 2s, change the load, short press the indicator will change the load's status. Note: The programming channel is from channel 1 to channel 8, and then it will go back to the channel 1. If you want to set multiple channels, the panel must be set to "Combination mode".
- 4. Choose a button which is used to control the channel. Keep pressing the button, it will cover the original targets, short press the button, it will add the relay loads.
- 5. Keep pressing the Indicator for 10 seconds to finish the programming.

This function is to be used in conjunction with the new generation of DLP.

Safety attention



- The screw down strength should not exceed 0.4Nm.
- Connect a breaker or fuse with each channel.
- Current in each channel is less than 10A.
- Installation position: Distribution box (DB).
- Do not make wrong connection on Bus interface, it will damage the Bus interface of this module.
- Avoid the rain or water into module, it will damage this device.
- Do not get AC voltage into Bus wire, it will damage all devices in the system.
- Ensure good ventilation.
- Avoid contact with liquids and aggressive gases.